

CITY OF SIERRA VISTA  
AMENDMENTS TO THE  
**INTERNATIONAL FUEL GAS CODE**  
2015 EDITION

The following provisions of the International Fuel Gas Code, 2015 Edition, as published by the International Code Council, Inc., are hereby amended as follows:

1. At Section 101.1, change to read: These regulations shall be known as the Fuel Gas Code of the City of Sierra Vista, hereinafter referred to as “this code.”
2. At Section 101.2, number the existing exception as Exception 1; Exception 2 to read: As an alternative to the provisions of this code, fuel gas piping systems, fuel-gas utilization equipment and related accessories in existing buildings undergoing repair, alteration or addition, and change of occupancy shall be permitted to comply with the International Existing Building Code.
3. At Section 103.1, change to read: Enforcement agency. There exists a Building Inspections Division under the Department of Community Development. The code official in charge thereof shall be known as the building official/administrator.
4. At Section 103.2, delete the entire section.
5. At Section 103.3, delete the entire section and renumber the remaining section 103.3.
6. At Section 106.6.2, delete the entire section and insert in lieu thereof the International Building Code, 2015 Edition, Section 109.2, as amended.
7. At Section 106.6.3, delete the entire section and insert in lieu thereof the International Building Code, 2015 Edition, Section 109.2, as amended.
8. At Section 303.7, insert subsection 303.7.1 to read: “Liquefied petroleum gas piping shall not serve any gas appliance located in a pit or basement where heavier-than-air gas might collect to form a flammable mixture.”
- ~~9. At Section 310.1, delete the last sentence.~~
- ~~10. At section 614.8.2, delete the last sentence and replace with, “Clothes dryer exhaust ducts shall not be connected with screws or fasteners which extend into the duct.”~~
11. Specifically adopt Appendices A, B, and D.